



SECTION 10155
TOILET COMPARTMENTS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Plastic laminate partitions.

1.2 RELATED SECTIONS

- A. Section 05500 - Metal Fabrications: Concealed steel support members.
- B. Section 06110 - Wood Framing: Concealed wood framing and blocking for compartment support.
- C. Section 10800 - Toilet and Bath Accessories.

1.3 REFERENCES

- A. ASTM International:
 - 1. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
 - 2. ASTM D2247-11, Standard Practice for Testing Water Resistance of Coatings in 100% Relative Humidity
 - 3. ASTM D1735-14, Standard Practice for Testing Water Resistance of Coatings Using Water Fog Apparatus
- B. United States Green Building Council (USGBC): LEED Green Building Rating System.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. [Product Data]: Manufacturer's data sheets on each product to be used, including:
 - 1. Literature indicating typical panel, pilaster, door, hardware and fastening.
 - 2. Preparation instructions and recommendations.
 - 3. Storage and handling requirements and recommendations.
 - 4. Installation methods.
- C. Shop Drawings:
 - 1. Dimensioned plans indicating layout of toilet compartments.
 - 2. Dimensioned elevations indicating heights of doors, pilasters, separation partitions, and other components; indicate locations and sizes of openings in compartment separation partitions for toilet and bath accessories to be installed in partitions; indicate floor and ceiling clearances.
 - 3. Details indicating anchoring components (bolt layouts) and methods for project conditions; indicate components required for installation, but not supplied by toilet compartment manufacturer.
- D. Selection Samples: For each finish product specified, one complete set of color selection

guides representing manufacturer's full range of available colors, textures and patterns.

- E. Verification Samples: For each finish product specified, two samples, minimum size 6 inches (150 mm) square, representing actual product, color, texture and pattern.
- F. LEED Green Building Rating System: Submit manufacturer's documentation of recycled content, in accordance with LEED credit calculations.
- G. Manufacturer's Certificates: Certify products meet or exceed specified requirements.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store and handle materials and products in strict compliance with manufacturer's instructions and recommendations and industry standards.
- B. Store products indoors in manufacturer's or fabricator's original containers and packaging, with labels clearly identifying product name and manufacturer. Protect from damage.
- C. Lay cartons flat, with adequate support to ensure flatness and to prevent damage to pre-finished surfaces.
- D. Do not store where ambient temperature exceeds 120 degrees F (49 degrees C).

1.6 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.
- B. Do not deliver materials or begin installation until building is enclosed, with complete protection from outside weather, and building temperature maintained at a minimum of 60 degrees F (15.6 degrees C).

1.7 WARRANTY

- A. Manufacturers Standard Warranty: Provide warranty for Plastic Laminate Material utilizing Moisture Guard Edge Banding: Against discoloration or delamination for 5 years, assuming proper maintenance according to manufacturer's recommendations.

1.8 COORDINATION

- A. Coordinate Work with placement of support framing and anchors in walls and ceilings.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: ASI Global Partitions, which is located at: 2171 Liberty Hill Rd.; Eastanollee, GA 30538; Tel: 706-827-2700; Fax: 706-827-2710; Email:[request info \(sales@globalpartitions.com\)](mailto:request_info@globalpartitions.com); Web:asi-globalpartitions.com
 - 1. Acceptable Alternate
 - a. ASI-Accurate located in McCook, IL
 - b. No other manufacturer will be accepted without ASTM performance compliance.
- B. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 COMPARTMENTS AND SCREENS

- A. Toilet Compartments: Ceiling hung.
 - 1. Compartment Depth and Width: As scheduled and indicated on Drawings.
 - 2. Door Width: As scheduled and indicated on Drawings.
 - 3. Height Above Floor: 12 inches (305 mm).
 - 4. Door/Panel Height: 58 inches (1473 mm).
 - 5. Pilaster Height: As scheduled and indicated on Drawings.
- B. Privacy and Urinal Screens: Wall hung.
 - 1. Screen Panel Size: 24 inches (610 mm) wide by 48 inches (1219 mm) high.
 - 2. Height Above Floor: 18 inches (457 mm).

2.3 PLASTIC LAMINATE TOILET COMPARTMENTS

- A. Doors, Panels, Screens, and Pilasters: Decorative plastic laminate bonded under pressure with non-toxic adhesive to wood core.
- B. Moisture Guard Edge Banding from ASI-Global or a product with performance measured by:
 - 1. ASTM D1735 - Water Fog Exposure; and exceeding 40 hours of exposure without failure.
 - 2. ASTM D2247 - Humidity Exposure and exceeding 40 hours of exposure without failure.
- C. Doors, Screens, and Panels: 7/8 inch (22 mm) thick particleboard; finished thickness of 1 inch (25 mm). All partition doors, panels, screens and pilasters to be supplied with Moisture Guard Edge Banding.
 - 1. Pilasters: 1-1/8 inches (29 mm) thick particleboard; finished thickness of 1-1/4 inch (32 mm). Pilaster to be provided with Moisture Guard Edge Band on all four (4) edges of pilaster.
- D. Finish: Plastic laminate, color as selected from manufacturer's standard colors.
- E. Door Hardware:
 - 1. Finish: Chromium plated Zamac attached with theft resistant barrel nuts and shoulder screws. Optional 304 Stainless Steel hardware available.
 - 2. Hinges: Top and bottom hinges recessed into door with saddle on adjacent pilaster, providing bi-directional operation about axis within the plane of the door; adjustable cams supporting door, returning to resting position by gravity.
 - 3. Strike and Keeper: Emergency access by lifting door.
 - 4. Latch: Manufacturer's standard surface mounted.
 - 5. Coat Hook and Bumper: Manufacturer's standard surface mounted. No tamper resistant screws required.
 - 6. Door Pull: Standard on ADA compartments.
 - 7. Fastening Hardware: Theft resistant heads.
- F. Pilaster Anchors: Ceiling Hung.
 - 1. 1/4 inch (6 mm) by 1 inch (25 mm) steel bar secured to pilaster with 3/8 inch (9.5 mm) cadmium plated studs; leveling adjustment concealed by pilaster shoe after installation.

PART 3 EXECUTION

3.1 EXAMINATION AND PREPARATION

- A. Inspect and prepare substrates using the methods recommended by the manufacturer for achieving best result for the substrates under project conditions. Clean surfaces thoroughly

prior to installation.

- B. Do not proceed with installation until substrates have been prepared using the methods recommended by the manufacturer and deviations from manufacturer's recommended tolerances are corrected. Commencement of installation constitutes acceptance of conditions.
- C. If preparation is the responsibility of another installer, notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions.
 - 1. Verify dimensions of areas to receive compartments.
 - 2. Verify locations of built-in framing, anchorage, bracing, and plumbing fixtures.

3.2 INSTALLATION

- A. Install in accordance with approved shop drawings and manufacturer's instructions.
- B. Fasten components to adjacent materials and to other components using purpose-designed fastening devices.
- C. Adjust pilaster anchors for substrate variations; conceal anchors with pilaster shoes.
- D. Equip each compartment door with top and bottom hinges and door latch.
- E. Install door strike keeper on pilasters in alignment with door latch.
- F. Equip each compartment door with one coat hook and bumper.
- G. Installation Tolerances:
 - 1. Maximum variations from plumb or level: 1/8 inch (3 mm).
 - 2. Clearance between wall surface and panels or pilasters: 1-1/2 inch (38 mm) maximum.

3.3 ADJUSTING

- A. Adjust and align hardware to uniform clearance at vertical edge of doors.
- B. Adjust adjacent components for consistency of line or plane.

3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. Remove factory protective coverings and clean finish surfaces in accordance with manufacturer's instructions before substantial completion.

END OF SECTION